



Eugene Water & Electric Board

500 East 4th Avenue
PO Box 10148
Eugene OR 97440-2148
541-685-7000
www.eweb.org

Name/Contractor _____

Address: _____

Service Address: _____

Subject: Commercial Small Services Backflow Prevention Requirements

The Oregon Plumbing Specialty Code (OPSC) and Oregon Administrative Rules (OAR) #333-061-0070 require backflow prevention when potable water comes into contact with any non-potable substance.

The following list includes, but is not limited to, common commercial water uses that require backflow protection:

- Fire suppression systems
- All irrigation systems
- Hydronic and geothermal heating systems
- Pools, hot tubs
- Water features (fountains, ponds etc.)
- Pumps (booster, circulating etc.)
- Soda Machines with direct water connection
- Any non-potable substance on site that poses risk to public health
- Water cooled equipment
- Laboratory facilities
- Medical, Dental or Veterinary equipment, with direct water connection
- Cannabis producing or processing facilities
- More than 3-story building

Backflow assembly installations shall meet OPSC and EWEB’s minimum installation standards and must be tested upon installation by a State of Oregon certified backflow assembly tester, with results submitted to EWEB within 10-days of test.

Water service is contingent upon compliance with these OPSC & OAR public health requirements. Your request for new water service will be processed within two days upon receipt of this signed document.

Signature _____ Print Name _____

Date _____ Daytime Telephone _____

If you have any questions, or need more information, please call EWEB Cross Connection Specialist at 541-685-7352.

NOTE: This agreement expires 30-days after final occupancy permit has been issued by the City of Eugene. If facilities do not comply with requirements of this letter upon expiration, corrections will be performed by EWEB and billed to you.